



**FRANKLIN COUNTY  
CONVENTION FACILITIES  
AUTHORITY**

**COLUMBUS**

400 N. High Street  
Columbus, OH 43215  
(614) 827-2800  
meetusincolumbus.com

**Addendum No.1  
Bid Package 2024-3  
Greater Columbus Convention Center  
South Facility Fire Pump Replacement**

Information contained within this Addendum No.1 modifies the November 8, 2024 Project Manual for the Greater Columbus Convention Center South Facility Fire Pump Replacement. Receipt of this Addendum must be indicated on the Form of Proposal (Bid) submitted by each bidder.

Clarification

Please see attached clarification from Heapy referring to drawing F101 addressing changes to vent piping from the new fuel oil tank.

Pre-Bid Meeting #2

A second pre-bid meeting and site visit will be held on Wednesday November 20, 2024, at 9:00 AM. The meeting will be held at the Franklin County Convention Facilities Authority's offices located at 400 N. High Street, 4<sup>th</sup> Floor, Columbus, Ohio 43215.

Please note that the bid submittal date and time remains unchanged.

Jordan Edmonds  
In-House Counsel, FCCFA



**Greater Columbus Convention Center  
South Building Fire Pump Replacement  
Addendum 1  
HEAPY PROJECT NO. 2024-07029**

**November 15, 2024**

**General**

- ITEM NO. 1 Clarification
- Refer to drawing F101
    - Note 10 for view A/F101 Partial Fire Suppression Floor Plan – New Work shall be revised to read as follows:  
Extend new 4" vent piping from new fuel oil tank up through slab, following path of existing 1.5" vent pipe that will be demolished. Piping to continue above slab, tight to building to a minimum of 12' above grade.

End of Addendum 1

**Attachments**

---

Cleveland • Columbus • Dayton • Findlay • Indianapolis • Raleigh